

In situ permeability measurement with the BAT Permeameter

Quick Manual Inflow test



BAT Geosystems AB
Box 1060
186 26 Vallentuna
Tel +46851170600
Fax +46851173361

BAT Geosystems AB
Hällebergsvägen 5
443 60 Stenkullen
Tel +46317890600
Fax +46851173361

www.bat-gms.com
info@bat-gms.com

Ver 2012-04-02



Warranty details

BAT Geosystems AB (BAT) warrants all new BAT products against defects in materials and workmanship for a period of 6 months from the date of invoice. During the warranty period, we will repair or, at our option, replace at no charge a product that proves to be defective provided that it is returned, shipping cost prepaid, to BAT.

BAT's liability and obligations in connection with any defects in materials and workmanship are expressly limited to repair or replacement, and the sole and exclusive remedy in the event of such defects shall be repair or replacement. BAT's obligations under this warranty are conditional upon it receiving prompt written notice of claimed defects within the warranty period and it's obligations are expressly limited to repair or replacement.

This warranty does not apply to products or parts thereof which have been altered or repaired outside of the BAT factory, or products damaged by improper installation or application, or subjected to misuse, abuse neglect or accident.

BAT Geosystems AB will not be liable for any incidental or consequential damage or expense incurred by the user due to partial or incomplete inoperability of it's products for any reason whatsoever or due to inaccurate information generated by its products.

All warranty service will be completed as soon possible. If delays are unavoidable customers will be contacted immediately.

	Page
Pre-test measures	2
Introduction of BAT Permeameter	3
BAT Permeameter Equipment	4
Equipment Parts	5
Assembly of equipment - Stepwise	6
Setup of inflow test	8
Starting the BAT Permeameter test	9
Finalizing the test	10
APPENDIX 1 Test Protocol - Inflow test	11
APPENDIX 2. Inflow Test. Recommended testing procedure	12
APPENDIX 3. Guide values of t_{80} for inflow test	13
APPENDIX 4 Input data-sheet for PC calculation	14
APPENDIX 5 Output sheet from PC-computation	15

1) Installation of BAT MKIII Filter Tip

Install a BAT MKIII Filter Tip at desired depth and location. Follow the instructions from the “Installation of the BAT MKIII Filter Tip”-guide.

2) Measurement of pore pressure

Measure the actual pore pressure. Follow the instructions given in the “BAT Pore Pressure Guide”.

Dissipation of disturbance effects

When the BAT Filter Tip is pushed into the soil, excess pore pressures will be generated due to disturbance effects. The time needed for dissipation of these disturbance effects varies with the type soil. In soft, plastic clays it may take several days until the original pore pressure is restored. On the contrary, in stiff clay, silt and fine sand the dissipation of the excess pressures goes much quicker. The process of dissipation of excess pore pressures can be logged by the BAT Sensor. Make sure that the installation disturbance pore pressure has dissipated before starting a permeability test. If unsure, leave the sensor connected to the BAT Filter Tip for 10 minutes. If, during this period, the reading is stable (± 0.01 m H₂O) a permeability test can be performed.

3) Checking BAT Sensor

Make sure that the battery unit of the sensor contains a fresh, alkaline battery. If unsure, change the battery. Normal life time of a battery when constant logging (1 minute interval) is about 3-4 weeks.

The BAT Permeameter can measure **permeabilities, k , in the range from $1 \cdot 10^{-7}$ m/s and lower.**

An example of typical k -values for different soil types:

Fine gravel:	$1 - 1 \cdot 10^{-2}$ m/s
Coarse sand:	$1 \cdot 10^{-1}$ m/s - $1 \cdot 10^{-3}$ m/s
Medium sand:	$1 \cdot 10^{-2}$ m/s - $1 \cdot 10^{-4}$ m/s
Fine sand:	$1 \cdot 10^{-3}$ m/s - $1 \cdot 10^{-5}$ m/s
Coarse silt:	$1 \cdot 10^{-4}$ m/s - $1 \cdot 10^{-6}$ m/s
Medium silt:	$1 \cdot 10^{-6}$ m/s - $1 \cdot 10^{-7}$ m/s
Fine silt:	$1 \cdot 10^{-7}$ m/s - $1 \cdot 10^{-8}$ m/s
Clay:	$< 1 \cdot 10^{-8}$ m/s

Typical time for stabilization for different k -values, i.e. time of testing, see also APPENDIX 3.

$k \approx 10^{-7}$ m/s ; $t_{stab} \approx 5$ minutes

$k \approx 10^{-8}$ m/s ; $t_{stab} \approx 10 - 50$ minutes

$k \approx 10^{-9}$ m/s ; $t_{stab} \approx 1-5$ hours

$k \approx 10^{-10}$ m/s ; $t_{stab} \approx 10-50$ hours

Theory of the BAT Permeability Test

The BAT Permeability Test is a type of "falling head" test. The evaluation of the test is made by using Hvorslev's equation *):


$$k = P_0 \cdot V_0 / (F \cdot t \cdot 10^3) \cdot \{ 1/U_0 \cdot P_0 - 1/U_0 \cdot P_m + 1/U_0^2 \cdot \ln[(P_0 - U_0)/P_0 \cdot P_m / (P_m - U_0)] \}$$

Parameters:

F	= Hvorslev's flow factor	mm
	BAT MKIII Standard: 230 mm	
	BAT MKIII Vadose: 194 mm	
k	= coefficient of permeability	m/s
U_0	= equilibrium pore pressure in-situ (absolute)	m H ₂ O
P_0	= initial system pressure (absolute)	m H ₂ O
P_m	= system pressure at time t (absolute)	m H ₂ O
V_0	= initial system volume of air	ml
t	= time for the test	s


At any time t the corresponding coefficient of permeability k can be calculated using Hvorslev's equation.

*) Hvorslev, M.J. 1951. "Time lag and soil permeability in ground water observations".



Contents:

- | | |
|--|--------------------------------|
| 1. Test container housing | 8. Syringes (25 ml & 10 ml) |
| 2. Test container (35 ml) | 9. Container for used needles |
| 3. Extension adapter | 10. Double ended needles |
| 4. Quick coupling sleeve | 11. Vacuum pump with Manometer |
| 5. Spare screws and springs | 12. Blue needles |
| 6. Screwdriver for mounting of double ended needle | 13. Cable Clamp |
| 7. Spare septas | |



PRECAUTIONS

- Handle all parts carefully, especially the glass containers.
- Use only sharp needles. Do not re-use needles.
- Store the set in a dry environment.
- Do not use any tools to assemble the set. Finger tight is enough.



Transfer nipple & extension adapter

- Screw the transfer nipple until it seats in the sensor cavity. Firstly, make sure the parts all are dry.
- Attach a blue needle onto the transfer nipple.
- Mount the extension adapter onto the transfer nipple.



Test Container

Container housing assembly and connection of Pressure Sensor and IS Field Unit

- Carefully insert the test container into the container housing.
- Screw the extension adapter onto the open end of the container housing. The Pressure Sensor is now connected to the Test Container.
- Connect the IS Field Unit, choose Display Mode.
- The pressure in the test container can now be measured with the IS Field Unit .



Application of initial system pressure P_0

Inflow Test

The initial system pressure P_0 in the Test Container is applied by either by extracting or injecting a volume of air by using a 25 ml syringe.



The volume of air to be extracted or injected is a function of the actual pore pressure U_0 .

See **page 7** for instructions regarding the application of the initial system P_0 in the test container.

Use the IS Field Unit for checking The actual pressure in the Test Container.

Do also check that the system is leakproof by reading the displayed pressure.





Saturated soil conditions & positive pore pressure situation INFLOW TEST

For saturated soil conditions it is recommended to carry out the BAT Permeability test as an inflow test. It is also assumed that a positive pore pressure situation is prevailing, i.e.:

$$\text{in which } U_0 > p_{\text{atm}}$$

$$U_0 = \text{equilibrium pore pressure (absolute pressure)} \quad (\text{m H}_2\text{O})$$

$$p_{\text{atm}} = \text{atmospheric pressure} \quad (\text{m H}_2\text{O})$$

The inflow test starts with an **empty** Test container.

For the inflow test it is recommended to use either the BAT MkIII Std Filter Tip or the BAT MkIII HD Filter Tip.

Recommended procedure

When conducting the Inflow Test it is recommended to adjust the initial pressure P_0 so that at 80% pressure recovery, i.e. at P_{80} , the water volume in the Test container, ΔW_{80} , will be in the order of 15 ml.

Depending on the magnitude of U_0 the initial pressure in the Test container P_0 can be adjusted either **by extracting or injecting** a volume of air, ΔV_{air} from/to the Test Container.

in which:


- P_0 = initial pressure in Test container
- ΔV_{air} = extracted or injected volume of air out of or into the Test container
- P_{80} = pressure in Test container at 80% pressure recovery
- ΔW_{80} = volume of water in Test container at P_{80}

See **APPENDIX 2** for more details about this recommended procedure.

Combined discrete sampling of porewater and permeability testing

The BAT Permeability test can be combined with a simultaneous collection of a porewater sample for chemical analysis. In this case, it is recommended to evacuate the test container by using the hand vacuum pump for creating highest possible vacuum. Maximum achievable vacuum using the hand pump is in the order of 90%.

The logged pressure/time data from the filling of the Test container can readily be used for evaluation of the k -value for the tested soil.



Hand-vacuum pump for evacuation of the Test container.


- Assemble the Luer lock coupling
- Insert the Test container into the Guide sleeve
- Evacuate the test container

See APPENDIX 2 for setting of the recommended value system pressure P_0 .
With the system pressure P_0 set correctly the next steps are as follows:

Temperature equilibrium

With knowledge of the installation depth, use the cable clamp to fix the cable and let the BAT Permeameter rest some 0.5 meter above the filter tip before starting the test.

With the BAT/IS-Field Unit connected you can now monitor the pressure change that occurs in the Test container due to change of temperature. Temperature equilibrium is normally reached after about 15 to 20 minutes. When the system pressure P_0 is stable **note the P_0 value** in the Test Protocol., see APPENDIX 1.



Cable clamp to fix the cable during temperature equalization.

Starting the test

- 1) Prior to the start of the test, prepare the Field Unit by opening the "Start Measure" menu. Select both sensor and temperature logging (sensor+temp) and a suitable time interval.
- 2) To start with it is recommended to use 1 min logging interval. At a later stage of the test, the logging interval can be increased, without any interference with the ongoing logging of test data, see paragraph 6) below.
- 3) Thereafter, return once more to the "Start Measure" menu and just place the marker on the OK-option, without starting the logging.
- 4) The next step is to connect the test equipment to the BAT Filter Tip. Thus, remove the cable clamp and gently lower the equipment the remaining distance down to the Filter Tip. **At the same moment** the equipment connects to the Filter Tip, **press OK** on the Field Unit and the test is running. **Open the "Display" menu** of the Field Unit to have a visual check that the test is running, i.e. the pressure shall gradually change.
- 5) Depending on soil type the time of testing may vary from about 5 minutes up to 24 hours or more.
- 6) After about one hour of logging it is recommended to increase the measuring interval of the sensor to 10 minutes or more. This is simply done by activating the "Start measure" function of the BAT/IS-Field Unit and select a new logging interval.

7) Finalizing the permeability test

It is recommended to evaluate the permeability of the tested soil at a **pressure equalization 80 % , i.e. at pressure level P_{80}** .

When finalizing the test the by following the following steps shall be taken:

- A) Note the values of system pressure P_{end} and atmospheric pressure p_{atm} in the Test Protocol, APPENDIX 1.
NB. In case a substantial change of the atmospheric pressure p_{atm} has occurred during the test this has to be taken into account when evaluating the test results.
- B) Gently pull up the equipment and measure the volume of water W_{end} in the test container. The W_{end} -value shall be noted in the Test Protocol. The volume can be measured by pouring the liquid into a syringe sealed with a rubber septa to the needle. It can also be measured more accurately using a scale at the office at a later stage.
- C) Now the field part of the test is completed.
Processing of test data and evaluation of the coefficient of permeability k_{80} can be done by using an Excel sheet shown in APPENDIX 3.
NB. If running more tests before downloading the data to a PC, just remember **do not clear the data between the tests**. Keep notes on the starting time and starting pressures of each test and each set of test data so that the tests can be easily separated when processing it on a PC.
An Output Excel sheet with evaluated test data and diagrams is shown in APPENDIX 4.

D) Checking the quality of the permeability test

The quality of permeability can be checked by calculation of the water volume ratio:

$$W_{end}/W_{calc}$$

in which W_{end} = measured water volume in the Test container (ml)
 W_{calc} = calculated water volume in the Test container (ml)

For approval of the test the water volume ratio shall fulfil the following requirement: :

$$0,9 \leq W_{end}/W_{calc} \leq 1,1$$

NB. In case the soil contains free gas the water volume ratio will normally be: $W_{end}/W_{calc} < 0,9$

Site:..... Date:.....

Measuring point.: BAT/IS sensor nr.:

Installation depth of filter tip:..... Test performed by :.....

Initial atmospheric pressure :m H₂O time:

Final atmospheric pressure :m H₂O time:

Type of Filter Tip: ☐ BAT MkIII Standard Filter Tip
 ☐ BAT MKIII Vadose Filter Tip
 ☐ BAT MKIII HD Filter Tip

NOTE! ALL PRESSURES ARE IN ABSOLUTE VALUES!

U₀, pore pressure at equilibrium, m H₂O:.....
 (U₀ = U_m + 0.2 mH₂O)

P₀, system pressure at start of test (at temperature equilibrium), m H₂O:.....
 (displayed P_m value)

P₈₀, system pressure at 80% pressure recovery, m H₂O:
 P₈₀ = P₀ + 0,8(U₀ - P₀)

P_{end}, final system pressure, m H₂O:.....

W_{calc}, calculated volume liquid in system at end of test, ml:.....

$$W_{calc} = 35 - (P_0 * 35) / P_{end}$$

W_{end}, measured volume liquid in sample container at end of test, ml:

Coefficient of permeability, k =*10⁻ m/s, calculated at% pressure equalization

Notes:.....




Diagram for evaluation of ΔV_{air} as a function of U_0

Parameters

ΔV_{air} = extracted or injected volume of air out of or into the Test Container ml

U_0 = equilibrium pore pressure (absolute pressure) m H₂O

ΔW_{80} = volume of water in Test container at 80% pressure recovery ml

P_0 = initial pressure in Test container (absolute pressure) m H₂O

P_{80} = pressure in Test container at 80% pressure recovery m H₂O

Evaluation of ΔV_{air} as a function of U_0 at $\Delta W_{80} = 15$ ml

The above diagram enables evaluation of ΔV_{air} as a function of U_0 valid for a volume of water in the Test container of $\Delta W_{80} = 15$ ml .

Example 1.

$U_0 = 15$ m H₂O gives $\Delta V_{air} = -7,5$ ml (extraction) and a corresponding P_0 equal to about 7,8 m H₂O.

Example 2.

$U_0 = 25$ m H₂O gives $\Delta V_{air} = 10$ ml (injection) and a corresponding P_0 equal to about 13m H₂O.

U_o m H ₂ O	t80,hrs $k_{80}=1,0E-8$ m/s	t80,hrs $k_{80}=5,0E-9$ m/s	t80,hrs $k_{80}=1,0E-9$ m/s	t80,hrs $k_{80}=5,0E-10$ m/s	t80,hrs $k_{80}=1,0E-10$ m/s
12	0,6	1,1	5,6	11,1	55,6
15	0,4	0,8	4,2	8,4	41,8
20	0,3	0,6	3,1	15,6	31,1
25	0,2	0,5	2,4	12,2	24,3
30	0,2	0,4	1,9	9,7	19,4
35	0,2	0,3	1,6	8,1	16,1
40	0,1	0,3	1,4	6,9	13,9
45	0,1	0,2	1,2	6,1	12,2
50	0,1	0,2	1,1	5,6	11,1
55	0,1	0,2	1,0	5,2	10,4
60	0,1	0,2	1,0	4,9	9,7
65	0,1	0,2	0,9	4,6	9,2
70	0,1	0,2	0,8	4,2	8,3
75	0,1	0,2	0,8	3,9	7,8
80	0,1	0,1	0,7	3,6	7,2

NB. U_0 Absolute pressure

Calculated guide values of t_{80} , i.e. time needed for 80% of pressure recovery in an inflow permeability test, performed in accordance with the recommendations given in APPENDIX 2.

The value of t_{80} is a function of both the pore pressure U_0 and the coefficient of permeability k_{80} as can be seen from the above table.

For intermediate k_{80} values the corresponding t_{80} values can simply be calculated by linear interpolation. ΔW_{80} = volume of water in Test container at 80% pressure recovery.

Site	Regions Hus 2	Fill these cells with the starting parameters before calculation		In these columns you paste data from the IS-sensor. If needed, replace all dots with commas.			
Date	2012-02-27						
Installation depth of filterpit	43 m						
BAT/IS sensor no.	PA3822						
Operator	ST						
Length of filter, mm	35	(Standard Mk III = 35 mm) (Vadose Mk III = 35 mm)					
Diameter of filter, mm	31,5	(Standard Mk III = 31,5 mm) (Vadose Mk III = 25 mm)					
Flow factor, mm	229,6						
P_{s0} , m H ₂ O	8,22	Initial system pressure					
P_{s0} mH ₂ O	0,3	Final water column in test container		$k_{s0}= 2,34E-10$ $t_{s0}= 4:40:00$			
V_0 , ml	35	Initial air volume					
U_0 , m H ₂ O	51,00	Static pore pressure					
Air pressure, Pa	95230						
P_{s0} mH ₂ O	50,85						
W_{calc} , ml	29,30	Calculated volume of water after test					
W_{end} , ml	26,83	Measured volume water after test					
P_{80}	42,44	P80 = System pressure at 80% pressure equalization. It is recommended to evaluate k-value at this pressure level					
P_{50}	29,61	P50: System pressure at 50% equalization.					
Date	Time	Pressure Pa	Time elapsed	Time elapsed seconds	System pressure m H2O	Water volume in test container,ml	Permeability k [m/s]
1	2	3	5	6	8	10	11
2011-11-10	09:10:00	80677,5	0:00:00	0	8,22	0,00	
2011-11-10	09:23:00	88661,2	0:10:00	600	9,23	3,15	6,57E-10
2011-11-10	09:30:00	95929,5	0:20:00	1200	9,99	5,56	5,35E-10
2011-11-10	09:40:00	103448	0:30:00	1800	10,76	7,70	4,80E-10
2011-11-10	09:50:00	110989	0:40:00	2400	11,54	9,56	4,42E-10
2011-11-10	10:00:00	118671	0:50:00	3000	12,33	11,21	4,13E-10

Downloading of and processing of measurement data

The procedure for downloading and processing of measurement data is described in BAT's manual for pore pressure measurement "BAT/IS- system for Pore pressure measurement. Make sure macros are activated.

Insertion of measurement data in Excel calculation sheet

- 1) Insert the the data from the Test Protocol into Input sheet.
- 2) Paste the downloaded data in the columns 1, 2 and 3.

If present, change the "dots" to "commas" in the pressure column.

Output sheet from PC-computation

APPENDIX 5



Site	Office	Filter Type	BAT MKIII Standard
Point	3	Sensor #	PA3221
Installation depth	43m		BAT Permeameter test info@bat-gms.com www.bat-gms.com
Date	2012-01-15		
Operator	ST		

Initial pore pressure U_0 51 mH₂O
 Initial system pressure P_0 8,22 mH₂O
 Final water volume (measured) W_{end} 26,83 ml
 Final water volume (calculated) W_{calc} 29,3 ml
 Water volume ratio W_{end}/W_{calc} 0,92
 Final pressure P_{end} 50,87 mH₂O
 Pressure equalization 99,7% Pressure equalization
Calculated permeability: k_{80} **2,34E-10 m/s @ 4:40:00 hrs**
 at system pressure: P_{80} 42,44 mH₂O

